

2008 REGULATED SUBSTANCES

SUBSTANCE	YEAR SAMPLED	MCL	MCLG	AMT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
FLUORIDE	2008	4	4	1.1ppb		NO	Erosion of natural deposits Water additive-promoting stronger Teeth, discharge from fertilizer and aluminum factories
Haloacetic acids (HA5's - ppb)	2008	60	NA	19	9-34	NO	By product of drinking water disinfection
TTHM'S							
(Tot. Trihalomethanes) ppb	2008	80	0	38	31-38	NO	By product of drinking water disinfection
Dist. Chlorine AVERAGE	2008	4	NA	0.80	0.25-1.36	NO	HIGHEST RUNNING

TAP TURBIDITY MEASUREMENT DATA							
HIGHEST SINGLE MEASUREMENT		LOWEST MONTHLY % MEETING .3 NTU LIMIT		VIOLATION yes/no	MAJOR SOURCE		
(NOT EXCEED .3 NTU)	0.10	100%	0.95	NO	Soil run-off		

SODIUM	2008	AMT DETECTED	RANGE LOW/HI	TYPICAL SOURCE			
		8 mg/l	NA	EROSION OF NATURAL DEPOSITS			

LEAD & COPPER DATA								
		VIOLATION	ACTION LEVEL	MCLG	DETECTED 90 TH %TILE	HOMES ABOVE ACTION LEVEL		
&	LEAD	2008	NO	15	0	8 ppb	0	CORROSION OF PLUMBING
	COPPER	2008	NO	1.3	0	299 ppm	0	EROSION OF NATURAL DEPOSITS